

Telephone No - 0474 2994773  
E-mail - qcclkollam@gmail.com



**QUALITY CONTROL DISTRICT LABORATORY**  
**KERALA WATER AUTHORITY**  
**CANTONMENT P O, KOLLAM - 691 001**  
**REPORT ON ANALYSIS OF WATER**

Report No - 2023/QCDKLM/1088		Date: 06/03/2023		
Customer Name & Address		1. Date of Sample received: 02/03/2023		
St JOSEPH INTERNATIONAL SCHOOL, CHITTUMALA, EAST KALLADA.P.O, KOLLAM - 691 502 8943302833		2. Sampling done by: Customer		
		3. Sample Quantity : 250 ml		
		4. Source of Sample : Well Water		
		5. Sample Code : 2023/QCDKLM/1088		
		6. Test Performing Dates From : 02/03/2023 To : 06/03/2023		
Sl. No.	Parameters	Acceptable limits as per IS 10500 - 2012	Test Method	Result
1	Total Coliforms	Shall not be detected/100 ml	IS 15185 : 2016 ISO 9308 - 1 : 2014	ABSENT
2	E.coli	Shall not be detected/100 ml	IS 15185 : 2016 ISO 9308 - 1 : 2014	ABSENT

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

*Himes*  
Authorized By

\* End of Report \*

BACTERIOLOGIST  
QUALITY CONTROL DISTRICT LAB  
KERALA WATER AUTHORITY



QUALITY CONTROL DISTRICT LABORATORY  
KERALA WATER AUTHORITY  
CANTONMENT PO, KOLLAM - 691 001

TC-9565

Test Report

ULR - TC95652300000956F

Sl. No.	Characteristics	Unit	Test Method	Maximum Acceptable limits as per IS 10500 - 2012	Re
1	Turbidity	(NTU)	IS 3025 (Part 10): 1984 Nephelometric Method	1	<
2	pH at 25°C	-	IS 3025 (Part 11): 2022 Electrometric Method	6.5 to 8.5	7.
3	Total Hardness (as CaCO <sub>3</sub> )	(mg/L)	IS 3025 (Part 21) : 2009 EDTA Method	200	
4	Chloride (as Cl)	(mg/L)	IS 3025 (Part 32) : 1988 Argentometric Method	250	7
5	Electrical Conductivity at 25°C	(micro mhos/cm)	IS 3025 (part 14) - 1984	-	45
6	Iron (as Fe)	(mg/L)	IS 3025 (part 53) - 2003 1,10 Phenanthroline Method	1.0	0
7	Nitrate (as NO <sub>3</sub> )	(mg/L)	APHA 23rd Edition 4500 - NO <sub>3</sub> <sup>-</sup> B: 2017 UV Spectrophotometric Screening Method	45	1

Report No - 2023/QCDKLM/1027	Date of Issue : 27/02/2023
Customer Name & Address	1. Date of Receipt : 24/02/2023
St JOSEPH INTERNATIONAL SCHOOL, CHITTUMALA, EAST KALLADA, KOLLAM - 691 502 8943302833	2. Sampling done by : Customer
	3. Sample Code : 2023/QCDKLM/1027
	4. Source of Sample : Well Water
	5. Sample Quantity : 2 Litres
	6. Test Performing Dates
	From : 25/02/2023 To : 27/02/2023

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full with written approval of the Laboratory.

Verified By  
*[Signature]*

Name : FOUSIYA.S  
Sanitary Chemist

Authori  
*[Signature]*

Name:

Senior Sanitary  
QUALITY MANAGEMENT SYSTEM  
QUALITY CONTROL DISTRICT LAB  
KERALA WATER AUTHORITY  
KOLLAM

\* End of Report \*

KWA/KLM/R/19

Issue No. 01

Issue Date: 01.02.2021

Rev. No. 03

Rev. Date: :

Page 1 of 1

*[Signature]*  
PRINCIPAL  
St. Joseph International School  
Chittumala, East Kallada  
Kollam-691502

*[Signature]*  
MANAGING DIRECTOR  
St. Joseph International School  
Chittumala, East Kallada  
Kollam-691502