



**QUALITY CONTROL DISTRICT LABORATORY  
KERALA WATER AUTHORITY  
CANTONMENT P O, KOLLAM - 691 001**

☎ 0474 2994773    ✉ qcddlkollam@gmail.com



**Test Report**

U.L.R: TC956524000001926F Date of Issue: 15/05/2024

Report No: 2024/QCDKLM/2203 1. Date of Receipt: 14/05/2024

Customer Name & Address: 2. Sampling done by: Customer

**ST JOSEPH INTERNATIONAL  
SCHOOL  
CHITTUMALA,  
EAST KALLADA P.O  
KOLLAM - 691502  
9809692733**

3. Sample Code: 2024/QCDKLM/2203

4. Source of Sample: Open Well Water

5. Sample Description: Drinking water

6. Sample Quantity: 2 Litres

7. Test Performing Dates  
From: 15/05/2024 To: 15/05/2024

| Sl. No. | Characteristics | Unit | Test Method                                  | Maximum Acceptable limits as per IS 10500 - 2012 | Result |
|---------|-----------------|------|--|--|--------|
| 1       | pH at 25°C      | -    | IS 3025 (Part 11): 2022 Electrometric Method | 6.5 to 8.5                                       | 4.33   |

NB - The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory. The results apply to the sample as received. Sample will be retained only for 7 days after reporting the test results.

**Verified By  
Syma S  
Sanitary Chemist**

**QUALITY MANAGER  
Authorized By  
QUALITY CONTROL DISTRICT LAB  
KERALA WATER AUTHORITY  
Senior Sanitary Chemist**

\* End of Report \*



**QUALITY CONTROL DISTRICT LABORATORY**  
**KERALA WATER AUTHORITY**  
**CANTONMENT P O, KOLLAM - 691 001**

**REPORT ON ANALYSIS OF WATER**

| Report No - 2024/QCDKLM/2203  |                        | Date: 17/05/2024                         |                 |        |
|---|------------------------|--|-----------------|--------|
| Customer Name & Address   |                        | 1. Date of Sample received: 14/05/2024   |                 |        |
| <b>ST JOSEPH INTERNATIONAL SCHOOL</b><br>CHITTUMALA,<br>EAST KALLADA P.O<br>KOLLAM - 691502<br>9809692733 |                        | 2. Sampling done by: Customer            |                 |        |
|   |                        | 3. Sample Quantity : 250 ml              |                 |        |
|   |                        | 4. Source of Sample : Open Well Water    |                 |        |
|   |                        | 5. Sample Code : 2024/QCDKLM/2203        |                 |        |
|   |                        | 6. Test Performing Dates                 |                 |        |
|   |                        | From : 14/05/2024 To : 17/05/2024        |                 |        |
| Sl. No.   | Parameters             | Acceptable limits as per IS 10500 - 2012 | Test Method     | Result |
| 1   | Total Coliforms/100 ml | Shall not be detected/100 ml             | IS 15185 : 2016 | ABSENT |
| 2   | E. coli /100 ml        | Shall not be detected/100 ml             | IS 15185 : 2016 | ABSENT |

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Authorized By

**BACTERIOLOGIST**  
**QUALITY CONTROL DISTRICT LAB**  
**KERALA WATER AUTHORITY**  
**KOLLAM**

\* End of Report \*