



FAMILY HEALTH CENTRE

EAST KALLADA

EAST KALLADA PO KOLLAM

Pin 691502. Ph

Email-eastkph@gmail.com

CERTIFICATE OF SANITARY FITNESS

No:PH-15./2024

Certified that the sanitary arrangements made by the applicant/s

Mr/Mrs/Ms ST. Joseph international School The proprietor/s of wood of East kallada
village in building nos 495 of East kallada Gramapanchayathu are satisfactory to run School
at the time of my inspection on 20/05/2024

This certificate is issued to present before the secretary East kallada Gramapanchayathu for obtaining the license to industries, factories, trade, entrepreneurship activities and other services.

Place: East kallada

Date: 22/05/2024



Deepa
HEALTH INSPECTOR
PRIMARY HEALTH CENTRE
EAST KALLADA

Ref : Application no:

dated: 22/05/2024

Chelan no:GRN:

KL005614007202425E



QUALITY CONTROL DISTRICT LABORATORY
KERALA WATER AUTHORITY
CANTONMENT P O, KOLLAM - 691 001

REPORT ON ANALYSIS OF WATER

Report No - 2024/QCDKLM/2203		Date: 17/05/2024		
Customer Name & Address		1. Date of Sample received: 14/05/2024		
ST JOSEPH INTERNATIONAL SCHOOL CHITTUMALA, EAST KALLADA P.O KOLLAM - 691502 9809692733		2. Sampling done by: Customer		
		3. Sample Quantity : 250 ml		
		4. Source of Sample : Open Well Water		
		5. Sample Code : 2024/QCDKLM/2203		
		6. Test Performing Dates		
		From : 14/05/2024 To : 17/05/2024		
Sl. No.	Parameters	Acceptable limits as per IS 10500 - 2012	Test Method	Result
1	Total Coliforms/ 100 ml	Shall not be detected/100 ml	IS 15185 : 2016	ABSENT
2	E. coli /100 ml	Shall not be detected/100 ml	IS 15185 : 2016	ABSENT

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Authorized By

BACTERIOLOGIST
QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
KOLLAM

* End of Report *

KWA/KLM/R/19 Issue No. 01 Issue Date: 06.01.2024 Rev.No. 00 Rev. Date: 00



QUALITY CONTROL DISTRICT LABORATORY
KERALA WATER AUTHORITY
CANTONMENT P O, KOLLAM - 691 001
☎ 0474 2994773 ✉ qcdlkollam@gmail.com



Test Report

ULR: TC956524000001926F		Date of Issue: 15/05/2024			
Report No: 2024/QCDKLM/2203		1. Date of Receipt: 14/05/2024			
Customer Name & Address:		2. Sampling done by: Customer			
ST JOSEPH INTERNATIONAL SCHOOL CHITTUMALA, EAST KALLADA P.O KOLLAM - 691502 9809692733		3. Sample Code: 2024 QCDKLM/2203			
		4. Source of Sample: Open Well Water			
		5. Sample Description: Drinking water			
		6. Sample Quantity: 2 Litres			
		7. Test Performing Dates From: 15/05/2024 To: 15/05/2024			
Sl. No.	Characteristics	Unit	Test Method	Maximum Acceptable limits as per IS 10500 - 2012	Result
1	pH at 25°C	-	IS 3025 (Part 11): 2022 Electrometric Method	6.5 to 8.5	4.33

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory. The results apply to the sample as received. Sample will be retained only for 7 days after reporting the test results.

Verified By
Syma S
Sanitary Chemist

* End of Report *

QUALITY MANAGER
Authorized By
Sreeja R
Kerala Water Authority
Senior Sanitary Chemist

KWA/KLM/R/19

Issue No. 01

Issue Date: 01.02.2021

Rev. No. 04

Rev. Date: 08.11.2023