



**QUALITY CONTROL DISTRICT LABORATORY**  
**KERALA WATER AUTHORITY**  
**CANTONMENT P O, KOLLAM - 691 001**

**REPORT ON ANALYSIS OF WATER**

Report No - 2024/QCDKLM/2203		Date: 17/05/2024		
Customer Name & Address		1. Date of Sample received: 14/05/2024		
<b>ST JOSEPH INTERNATIONAL SCHOOL</b> CHITTUMALA, EAST KALLADA P.O KOLLAM - 691502 9809692733		2. Sampling done by: Customer		
		3. Sample Quantity : 250 ml		
		4. Source of Sample : Open Well Water		
		5. Sample Code : 2024/QCDKLM/2203		
		6. Test Performing Dates		
		From : 14/05/2024 To : 17/05/2024		
Sl. No.	Parameters	Acceptable limits as per IS 10500 - 2012	Test Method	Result
1	Total Coliforms/ 100 ml	Shall not be detected/100 ml	IS 15185 : 2016	ABSENT
2	E. coli /100 ml	Shall not be detected/100 ml	IS 15185 : 2016	ABSENT

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Authorized By

**BACTERIOLOGIST**  
**QUALITY CONTROL DISTRICT LAB**  
**KERALA WATER AUTHORITY**  
**KOLLAM**

\* End of Report \*

KWA/KLM/R/19 Issue No. 01 Issue Date: 06.01.2024 Rev.No. 00 Rev. Date: 00



QUALITY CONTROL DISTRICT LABORATORY  
KERALA WATER AUTHORITY  
CANTONMENT P O, KOLLAM - 691 001  
☎ 0474 2994773 ✉ qcdlkollam@gmail.com



Test Report

ULR: TC956524000001926F		Date of Issue: 15/05/2024			
Report No: 2024/QCDKLM/2203		1. Date of Receipt: 14/05/2024			
Customer Name & Address:		2. Sampling done by: Customer			
<b>ST JOSEPH INTERNATIONAL SCHOOL CHITTUMALA, EAST KALLADA P.O KOLLAM - 691502 9809692733</b>		3. Sample Code: 2024 QCDKLM/2203			
		4. Source of Sample: Open Well Water			
		5. Sample Description: Drinking water			
		6. Sample Quantity: 2 Litres			
		7. Test Performing Dates From: 15/05/2024 To: 15/05/2024			
Sl. No.	Characteristics	Unit	Test Method	Maximum Acceptable limits as per IS 10500 - 2012	Result
1	pH at 25°C	-	IS 3025 (Part 11): 2022 Electrometric Method	6.5 to 8.5	4.33

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory. The results apply to the sample as received. Sample will be retained only for 7 days after reporting the test results.

Verified By  
Syma S  
Sanitary Chemist

\* End of Report \*

QUALITY MANAGER  
Authorized By  
Sreeja R  
Kerala Water Authority  
Senior Sanitary Chemist

KWA/KLM/R/19

Issue No. 01

Issue Date: 01.02.2021

Rev. No. 04

Rev. Date: 08.11.2023